







PHOTO REPORT

Messr.

Date : 16th Nov 2017
Location : Singapore East IPL
Job No. : 3033

No.	Description	Pg1
	<p>Subject : <u>Servicing on Marine Package Air Conditioner @ Engine Control Room</u></p> <p>Maker : Johnson Controls Marine Type : SCU-E27 2 2FC Y113 Serial : S/N 009010006 Capacity : 23.90 KW Refrigerant 404A</p>	
	   	

No.	Description	Pg2
	  	
	 	
	 <p data-bbox="916 1570 1382 1644">Saginomiya Expansion Valve x 01pcs Type: ATX-57060DUS, 6.8 RT (23.9kW)</p> <p data-bbox="916 1688 1382 1832">Old expansion valve were gas cropped & removed. New copper pipe were built to install new expansion valve as seen in photo.</p>	

No.	Description	Pg3
	 	
	  <p>Emerson Liquid Filter Drier x 02pcs Type : EK 16 4S</p> <p>Existing filter were gas cropped & removed. New filter installed welded in place by brazing.</p> <p>One more unit supplied to vessel as spare.</p>	